

## Product certificate

Revision report no.: PR079

Certificate no.: PS329

This certificate confirms that:

Product name:	Pipes in polyethylene
Product type:	PE100
Product documentation:	Produktdatablad PE 100 trykkrør
Manufacturer:	Helgeland Plast AS, Båsmosjyen 4, 8616 Mo i Rana

Meets the requirements for strength and safety according to NS9416:2013,

Material:	Polyethylene 100	
Design lifetime:	100 years	
Product specifications:		
	Size group <sup>[1]</sup>	SDR
	1	9 – 11 – 13.6 – 17 – 21 – 26
	2	9 – 11 – 13.6 – 17 – 21 – 26
	3	9 – 11 – 13.6 – 17 – 21 – 26
	4	9 – 11 – 13.6 – 17 – 21 – 26

[1] Size group, i.e. nominal outer diameter  $d_n$  [mm]. 1:  $d_n < 75$ , 2:  $75 \leq d_n < 250$ , 3:  $250 \leq d_n < 710$ , 4:  $710 \leq d_n < 1800$ .

Criteria for validity:

Use and maintenance must be in accordance with requirements in product documentation.
Loads from other components must not exceed limits set in product documentation.
Validity period of certification <b>21.02.2020-21.02.2022</b> . <sup>[2]</sup>
The certificate is issued <b>21.02.2020</b> .

[2] The validity period of certification is related to the period which products can be distributed with the relevant product certificate.

The certificate is issued by:

Aquastructures AS  
Kjøpmannsgata 21, 7013 Trondheim

21.02.2020

Date



Aquastructures AS

Revision report is issued by:

